

JEFFREY T. PEARSON, P.E. Acting Director

> HELENE KAU Deputy Director

## DEPARTMENT OF WATER SUPPLY COUNTY OF MAUI

200 SOUTH HIGH STREET WAILUKU, MAUI, HAWAII 96793-2155 www.mauiwater.org

February 19, 2019

Honorable Michael P. Victorino Mayor, County of Maui 200 South High Street Wailuku, Hawaii 96793

For Transmittal to:

Honorable Riki Hokama Chair, Healthy Families and Communities Committee Maui County Council 200 S. High Street Wailuku, Hawai'i 96793

APPROVED FOR TRANSMITTAL

7 Vat 2.R.19

Dear Chair Hokama:

SUBJECT: NEW KAHULUI COMMUNITY CENTER FACILITY (HFC-7)

The 7.31 acre property on TMK (2) 3-8-007:180 overlies the Kahului Aquifer with a sustainable yield of 1 MGD according to the Commission on Water Resource Management.

The Department of Water Supply infrastructure includes one 12-inch water main located within approximately 100 feet of the property on South Kamehameha Avenue. A 36-inch transmission line runs adjacent to the property. The nearest fire hydrant lies within approximately 150 feet. Static pressure near the site was 48psi when tested in 2014. As this is near minimum, we will be performing a fire flow test on the 12-inch waterline along Kamehameha Avenue in the near future.

Elevation is approximately 200 feet or less. Soil is classified as PZUE with a sand and cemented material profile. Creating permeable surfaces in this somewhat restricted soil surface would be desirable to enhance recharge of the limited Kahului aquifer.

Sincerely,

JEFFREY T. PEARSON, P.E.

**Acting Director** 

xc: DWS Engineering Division